

Aqu@Fan II

10 ÷ 90




AWC



AWN



AHC



AHN

English

Français

Fan coil units

Ventilo-convecteurs

IOM AQF-N.4GBF

Date : **July / Juillet 2007**

Supersedes / Annule et remplace : **IOM AQF-N.3GBF/06.07**



INSTALLATION INSTRUCTION

NOTICE D'INSTALLATION

INSTALLATIONSHANDBUCH

ISTRUZIONI INSTALLAZIONE

INSTRUCCIONES DE INSTALACIÓN

English

Français

Deutsch

Italiano

Español

CONTENTS

GENERAL RECOMMENDATIONS	3
SAFETY DIRECTIONS.....	3
WARNING	3
INSPECTION AND STORAGE	4
WARRANTY	4
MODEL NOMENCLATURE.....	4
TECHNICAL SPECIFICATIONS.....	5
DIMENSIONS	5
NET WEIGHT	5
INSTALLATION	6
CLEARANCE	6
UNIT LOCATION	6
UNIT INSTALLATION.....	7
AWN / AWC CONSOLE UNIT	7
AHN / AHC CEILING UNIT	7
CABINET REMOVAL.....	8
CONDENSATE DRAIN LINE	8
WATER CONNECTIONS.....	9
OPERATING FACE	9
CHILLED WATER COIL - HOT WATER COIL.....	9
WATER COIL HEADERS.....	10
AIR VENTS AND DRAINS.....	10
COIL WATER SUPPLY AND RETURN	10
WATER CONNECTION DIAGRAMS OF CONTROL VALVES	10
INSTALLATION OF PIPE THERMOSTAT (CHANGE OVER)	10
TRM-FA AND TRM-VP.....	10
TAE20 AND AQUANET	10
ELECTRICAL CONNECTIONS.....	11
WIRING DIAGRAM AND LEGEND	11
POWER SUPPLY.....	11
ELECTRICAL CONNECTIONS	11
OPTIONAL ELECTRIC HEATER.....	12
CONTROLS	12
UNIT INITIAL START-UP	13
FINAL TASKS	13
MAINTENANCE.....	13
REGULAR MAINTENANCE	13
GENERAL INSPECTION	13
FOOT COVER REMOVAL.....	13
AIR FILTER	14
AIR FILTER REMOVAL	14
CONDENSATE DRAIN PAN	15
MODELS 20 TO 70:	15
MODELS 10. 80. 90:	15
COILS	15
FAN MOTOR ASSEMBLY	15
IN CASE OF WARRANTY - MATERIAL RETURN PROCEDURE	16
ORDERING SERVICE AND SPARE PARTS ORDER	16



POWER SUPPLY MUST BE SWITCHED OFF BEFORE STARTING WORK IN THE ELECTRIC CONTROL BOX

GENERAL RECOMMENDATIONS

Please read the following safety precautions very carefully before installing the unit.

SAFETY DIRECTIONS

Follow the safety rules in forces when you are working on your appliance.

The installation, commissioning and maintenance of these units should be performed by qualified personnel having a good knowledge of standards and local regulations, as well as experience of this type of equipment.

The unit should be handled using lifting and handling equipment appropriate to the unit's size and weight.

Any wiring produced on site must comply with the corresponding national electrical regulations.

Make sure that the power supply and its frequency are adapted to the required electric current of operation, taking into account specific conditions of the location and the current required for any other appliance connected with the same circuit.

The unit must be EARTHED to avoid any risks caused by insulation defects.

It is forbidden to start any work on the electrical components if water or high humidity is present on the installation site.

WARNING

Cutoff power supply before starting to work on the appliance.

When making the hydraulic connections, ensure that no impurities are introduced into the pipe work.

The manufacturer declines any responsibility and the warranty becomes void if these instructions are not respected.

If you meet a problem, please call the Technical Department of your area.

If possible, assemble the compulsory or optional accessories before placing the appliance on its final location. (see instructions provided with each accessory).

In order to become fully familiar with the appliance, we suggest to read also our Technical Instructions.

-The informations contained in these Instructions are subject to modification without advance notice.

INSPECTION AND STORAGE

At the time of receiving the equipment carefully cross check all the elements against the shipping documents in order to ensure that all the crates and boxes have been received. Inspect all the units for any visible or hidden damage.

In the event of shipping damage, write precise details of the damage on the shipper's delivery note and send immediately a registered letter to the shipper within 48 hours, clearly stating the damage caused. Forward a copy of this letter to the manufacturer or their representative.

Fan coil units are shipped in individual cartons.

Never store or transport the unit upside down. Do not stand or transport the machines on end. For storing, each carton is marked with "up" arrows. It must be stored indoors, completely protected from rain, snow etc. The unit must not be damaged by changes in the weather (high and low temperatures). Excessively high temperatures (above 60 °C) can harm certain plastic materials and cause permanent damage. Moreover, the performance of certain electrical or electronic components can be impaired.

WARRANTY

The appliances are delivered fully assembled, factory tested and ready to operate.

Any modification to the units without the manufacturer's prior approval, shall automatically render the warranty null and void.

The following conditions must be respected in order to maintain the validity of the warranty:

- Commissioning shall be performed by specialised technicians from technical services approved by the manufacturer.
- Maintenance shall be performed by technicians trained for this purpose.
- Only Original Equipment spare parts shall be used.
- All the operations listed in the present manual shall be performed within the prescribed SCHEDULE.



THE WARRANTY SHALL BE NULL AND VOID IN THE EVENT OF NON-COMPLIANCE WITH ANY OF THE ABOVE CONDITIONS.

MODEL NOMENCLATURE

SEE APPENDIX

TECHNICAL SPECIFICATIONS

without Electric heating										
Size		10	20	30	40	50	60	70	80	90
Power supply	V	230V-50Hz ALTERNATIF								
Fan motor power	W	35	41	60	57	63	110	132	190	295
Fuse rating Am	A						2			
Fuse rating ASE / VDE	A						2			
Cable section mini	mm ²						3G1.5			

with Electric heating										
Size		10	20	30	40	50	60	70	80	90
Power supply	V	230V-50Hz ALTERNATIF								
Electric heating capacity BE1	W	200	300	500	600	750	900	1000		
Fuse rating Gg	A			4						
Fuse rating ASE / VDE	A					10				
Cable section mini	mm ²					3G1.5				
Electric heating capacity BE2	W	400	600	1000	1200	1500	1800	2000		
Fuse rating Gg	A	4		6		8		10	12	
Fuse rating ASE / VDE	A				10					16
Cable section mini	mm ²			3G1.5			3G2.5			
Electric heating capacity BE3	W	600	900	1500	1800	2250	2700	3000		
Fuse rating Gg	A		6		8	10	12		16	
Fuse rating ASE / VDE	A			10			12			
Cable section mini	mm ²		3G1.5			3G2.5				
Electric heating capacity BE4	W	X		1200	2000	2400	3000	3600	4000	
Fuse rating Gg	A			8	12		16		20	
Fuse rating ASE / VDE	A			10		16			25	
Cable section mini	mm ²			3G1.5		3G2.5			3G4	

IMPORTANT

These datas are given for guidance only. They must be checked at commissioning according to prevailing standards. They depend on the installation and the cables used.

A main fuse must mandatorily be provided on the power supply.

- Fuses not supplied
- Cables not supplied

DIMENSIONS

SEE APPENDIX

NET WEIGHT

Sizes	AWC	AWN	AHC	AHN
10	/	11	/	11
20	20	14	20	14
30	23	16	23	16
40	30	23	30	23
50	35	27	35	27
60	39	30	39	30
70	42	34	42	34
80	50	41	50	41
90	56	46	56	46

weight in kilograms

INSTALLATION




The unit is not designed to withstand weights or stresses from adjacent equipment, pipe work or constructions. Any foreign weight or stress on the unit structure could lead to a malfunction or a collapse with dangerous consequences for personnel and property. In such an event, the warranty shall be null and void.

Important notes :

- Inspect the fan coil unit nameplate stucked on the back of the unit chassis.
- **AWN / AWC** console units are to be installed vertically against a wall or on a floor using support feet.
- Only **AHN / AHC** ceiling units are designed for ceiling mounting.
- After installing the unit, please be sure that there is no more longitudinal and transversal counterslopes avoiding condensate evacuation.

CLEARANCE



UNIT LOCATION



The unit base shall be arranged as indicated in the manual. There could be a risk of personal injury or damage to property in the event of the unit being incorrectly supported.

The unit must be installed on a firm level foundation, of adequate strength to support its full operating weight.

1. It must be high enough to permit good drainage of defrost water with siphon
2. When locating unit give consideration to, and locate unit as remote as possible minimise noise, as heat pump loads are greatest at night time.
3. The unit must be pitched slightly towards condensate drain outlet to provide positive drainage of condensates.
4. All electrical and ductwork connections to the unit must be made via flexible connections to prevent transmission of vibration.
5. In addition to the service clearances noted on the dimension sheet it is essential that provision is made for adequate and safe service access.

Fan coil units are designed to be installed in a controlled environment. Each unit should be located on the installation plans. Inspect the carton for specific tagging numbers and references (models, size, left hand or right hand). The supply, return and condensation piping should be located accordingly making sure the piping will fit into the confines of the fan coil chassis and cabinet.

Note: on the fan coil units with cabinet **AWC** or **AHC**, the cabinet is out of line in comparison with the unit chassis. Provide sufficient space to make water and electrical connections.

UNIT INSTALLATION

AWN / AWC CONSOLE UNIT

All units are to be installed against a wall as a floor console with support feet, or wall mounting as per dimensional data. On the fan coil units equipped with support feet, we recommend you to fix the unit to the wall through the both oblong holes located on the upper part of the unit chassis.

On the **AWC** model, to hang the unit to the wall, it is necessary to remove the cabinet.

Drill holes on the wall in accordance to the dimensions mentioned. Install the fixing screws (contractor supply).

Place the chassis unit over the fixing screws through the oblong holes and screw it directly to the wall.

Ensure adequate space for pipings and electrical connection, and check side of connection.

AHN / AHC CEILING UNIT

The **AHN** / **AHC** units are designed for ceiling mounting. Recommended fixing by M8 threaded rod or 8 mm diameter anchor bolts (contractor supply).

When the **AHN** units are ducted at the inlet side, the controller return sensor must be located outside the fan compartment in order to ensure its good operation.

For the **AHC** model with cabinet, it is necessary to remove the cabinet before installing it.


Follow instructions for cabinet removal.

Drill holes in the ceiling in accordance with dimensions mentioned. Install the fixing screws (contractor supply).

Place the chassis unit on the fixing points and screw it directly to the ceiling, or to the veritable support.

The fan coil unit should be pitched towards the drain side, to facilitate condensate evacuation.

Recommended fixing by M8 threaded rod with H8 hexagonal nut or 8 mm diameter anchor.



Sizes	Dimensions (mm)					
	A	B	C(*)	D	E	F
10 **	360	210	100	360	150	16
20	500	210	100	360	150	16
30	685	210	100	360	150	16
40	870	210	100	360	150	16
50	1055	210	100	360	150	16
60	1240	210	100	360	150	16
70	1055	208	100	365	157	18
80	1240	208	100	365	157	18
90	1425	208	100	365	157	18

* On units with front air intake, dimension C is not required.

** Not available on version AWC and AHC.

CABINET REMOVAL



When removing cabinet do not pull or lift it up by the discharge grilles, to avoid any damages on articulated fasteners of the access doors.

On the **AWC** and **AHC** models, to hang the unit to the wall, it is necessary to remove the cabinet.

To achieve this:

- Remove the fastener screws from the access hatch situated at the right end of the unit, on the electrical connections side.
- Withdraw the four screws that hold the casing attached to the two chassis flanks.



- Then, lift the casing vertically by pulling its forwards. Place it carefully to one side.

CONDENSATE DRAIN LINE



After installing the unit, be sure that there is no more longitudinal and transversal counterslopes avoiding condensate evacuation.

For that, use a square and spirit level to make sure that fan coil unit is level and that it is at a 90 degree angle between the wall and floor (see fluorescent sticker on unit chassis).

Note : If the floor and the wall are not at right angle, it may be necessary to shim the fan coil unit to insure proper installation. Manufacturer will not accept any responsibility on units not being on proper level.

Each fan coil unit is supplied with a 16 mm ID condensate S-shaped pipe. The drain pipe extends approximately 60 mm out of the piping compartment, to ensure either floor or wall connection to the main drain piping.

For the special case of a horizontal encased **AHC** unit, you must follow the connections as shown below:




WATER CONNECTIONS

OPERATING FACE

The operating face of Left/Right versions is defined in relation to the position of the hydraulic connections when the unit is viewed facing the operator.

Note: In the example below, the operating face is on the left.



CHILLED WATER COIL - HOT WATER COIL

Fan coil units are equipped, in standard 2 pipe system configuration, with a main 2 row chilled water coil or optional 3 row coil.


On 4 pipe system the unit will be factory mounted with 2 row or 3 row chilled water coil and 1 row complementary heating coil.

Note:

- The 4 pipe battery comprises a single finned block for sizes 10.80.90.
- The 4 pipe battery comprises two finned blocks for sizes 20.30.40.50.60.70.

Configuration with 3 row chilled water coil+1 row complementary heating coil or electric heater. Left hand connections.

Air vents orifices Coils 4 row



Complementary row : 10 - 80 -90


Complementary coil: 20 to 70

WATER VOLUME OF COILS

Minimum inlet temperature:+ 6 °C

Maximum inlet temperature:+ 90 °C

Air vents orifices Electric heater with mono-tube type heating elements located in heat exchanger



Sizes	Water volume (liters)		
	1-row	2-row	3-row
10	0.17	0.29	0.41
20	0.24	0.43	0.62
30	0.34	0.62	0.90
40	0.43	0.80	1.18
50	0.52	0.99	1.46
60	0.61	1.17	1.73
70	0.69	1.49	2.19
80	0.92	1.76	2.60
90	1.06	2.04	3.60

WATER COIL HEADERS

Each water coil header has 1/2" female threaded pipe connection for water supply and water return.



Do not push the coil headers to interior of unit casing, when tightening the screws of water connections.


AIR VENTS AND DRAINS

Coil headers have air vents and drains. Air vent is located at the upper part of the coil header, while drain is located at the lower part.

COIL WATER SUPPLY AND RETURN

Due to the coil design and small effect on capacity, there is no preferential water supply and water return on fan coil units. However we recommend water supply on the lower header of the coil.

WATER CONNECTION DIAGRAMS OF CONTROL VALVES




INSTALLATION OF PIPE THERMOSTAT (CHANGE OVER)

TRM-FA AND TRM-VP



The pipe thermostat (change-over switch) supplied is to be mounted on the water supply pipe.

Crimp the 6.35 F fast-on clips with their insulator bushes (supplied) on the wires of this thermostat.



OPERATING TEMPERATURE RANGE


Opening	$30 \pm 4^\circ C$
Closing	$15 \pm 4^\circ C$

AQU@FAN II

TAE20 AND AQUANET



The sensor (change over) supplied is to be fitted to the water inlet tube.



- Before assembling the change over sensor, coat the tube with heat conducting paste to guarantee that the real temperature is recorded.
- The 9 and 10 (electric terminal) change over sensor inputs are connected to the mains power supply. If it is necessary to extend the sensor wires, ensure that wires appropriate for this voltage are used.

SEE APPENDIX

ELECTRICAL CONNECTIONS

WARNING



Before carrying out any work on the equipment, make sure that the electrical power supply is disconnected and that there is no possibility of the unit being started inadvertently. Non-compliance with the above instructions can lead to injury or death by electrocution.

WIRING DIAGRAM AND LEGEND

SEE APPENDIX

SE3530	models 10 a 90 CMV	SE3534	models 10 a 90 CMV/TBV
SE3531	models 10 a 90 CMV/TBV	SE3535	models 10 a 90 AQUANET
SE3532	models 10 a 90 CMV/TBV1	SE3537	models 10 a 90
SE3533	models 10 a 90 CMV/TBMV1		

POWER SUPPLY

All fan coil units are designed for operation under 230 volts, single phase, 50 cycles.

A voltage variation of $\pm 10\%$ with regard to nominal voltage 230 V is acceptable.

ELECTRICAL CONNECTIONS

The electrical installation must be performed by a fully qualified electrician, and in accordance with local electrical standards and the wiring diagram corresponding to the unit model.

Any modification performed without our prior authorisation may result in the unit's warranty being declared null and void.

The power supply cable section must be sufficient to provide the appropriate voltage to the unit's power supply terminals, both at start-up and under full load operating conditions.

Before making the connections, be sure that the available power supply has the same voltage and phase as that shown on the fan coil unit nameplate.

Each fan coil unit is supplied with a terminal strip located on the opposite side of piping connections.

Line and low voltage wiring must be done in accordance with electrical code whichever is applicable. Earthing of unit is imperative.

Manufacturer or its representative cannot be held responsible for accidents resulting from incorrect or non-existent earthing.

A device to disconnect all the power conductors with an approved minimum opening distance must be included in the mains power supply according to best installation practices.

Note: if electrical wiring or conduit comes through the floor, they must be tight along their passage through the floor.



To perform electrical wiring of the unit, please refer to the wiring diagram pasted on the unit casing.

OPTIONAL ELECTRIC HEATER

On request, all fan coil units can be factory mounted with an electric heater.

The heating rod type electric heating is inserted directly into a finned exchanger.

The latter may be a single block unit for sizes 10, 80, 90 or with an additional block for sizes 20 to 70.

Do not install the electric heater on existing unit without using the supply air grilles resistant to high temperature.

Factory-fitted electric heating batteries are equipped with an automatic and manual reset temperature limiting safety device in compliance with IEC 66375.

Electric heater capacities Electric heaters with heating rods (supplied fitted)

Size	BE1	BE2	BE3	BE4
10	200	400	600 (1) (200+400)	ND
20	300	600	900 (1) (300+600)	ND
30	300	600	900 (1) (300+600)	1200 (1) (600+600)
40	500	1000	1500 (1) (500+1000)	2000 (1) (1000+1000)
50	600	1200	1800 (1) (600+1200)	2400 (1) (1200+1200)
60	750	1500	2250 (1) (750+1500)	3000 (1) (1500+1500)
70	750	1500	2250 (1) (750+1500)	3000 (1) (1500+1500)
80	900	1800	2700 (1) (900+1800)	3600 (1) (1800+1800)
90	1000	2000	3000 (1) (1000+2000)	4000 (1) (2000+2000)

(1) : Available in 2 steps suitable for Aqu@Net control.

NA : Not available.

CONTROLS

The standard units are supplied without any controls.

A manual fan speed selector or a remote control thermostat can be supplied as optional item.

If a TRM remote temperature regulation thermostat is supplied, it must only control a single unit. If this is not the case, you must include a relay box in the circuitry.

UNIT INITIAL START-UP

After installing the fan coil unit, water and electrical connections being made, it is imperative to re-install the cabinet on the **AWC** and **AHC** fan coil unit.

The cabinet will be fixed by the both screws, mentioned on section "Unit installation/Cabinet removal".

Before initial start up, be sure that the fan wheel is rotating free on its shaft.

Make sure that the filter is correctly positioned on its bracket.

FINAL TASKS

If needed, fix the cables and the pipes on the wall with clamping collars.

Operate the air conditioner in the presence of the user and explain all functions.

Show him how to remove, clean and place back the filters.

MAINTENANCE



The user is responsible for ensuring that it is in a proper working condition and that technical installation as well as the regular maintenance operations are performed by properly trained technicians and in accordance with the instructions contained in this manual.

REGULAR MAINTENANCE

These units have been designed for minimum maintenance through the use of permanently lubricated components. However, there are operational maintenance requirements that require regular attention to ensure optimum performance.

Maintenance must be performed by appropriately experienced personnel only.

WARNING : Isolate unit from power supply before working on unit.

GENERAL INSPECTION

Carry out a visual inspection of the complete installation in service.


Check the general cleanliness of the installation, and check if the condensate evacuations is not blocked, specially on the indoor coil, before the cooling season.

Check the condition of the condensate tray by pulling it out of the casing.

FOOT COVER REMOVAL

To remove the foot cover, press **1** and **2**, and push **3** as shown on photos.

To re-install it, do as above in the reverse way.



AIR FILTER

Changing the filter is a maintenance operation that should only be performed by qualified personnel.

To avoid clogging of air filter, it is recommended to clean it regularly.


Filter changes are required at the regular intervals. The time period between changes will depend upon the specific operating conditions.

Some applications such as hotels where there is a lot of lint from carpeting will require more frequent filter changes.

If light cannot be seen through the filter, when held up to sunlight or a bright light, it should be washed or changed.

AIR FILTER REMOVAL

1. On units with feet, remove the "MPG" grille (if present) and the foot cover at electrical side (see section "Foot cover removal").
2. Use a screwdriver to unlock the attachment system and then release the slide from the lug before pushing the slide downwards.



3. Repeat operation 2 on other sliding rail.
4. Take off the filter.

The attachment systems must be relocked in place after changing the filter.

Non compliance with these instructions can affect the unit's electrical safety and render the qualified personnel performing the work liable for any ensuing damage.

CONDENSATE DRAIN PAN

The condensate drain pan should be checked periodically and cleaned and rinsed if required.

MODELS 20 TO 70:

You can gain direct access to the condensates tray on non-encased units and after removal of the casing on encased units (See instructions in the chapter «Unit Installation / Casing removal») for encased units.

MODELS 10. 80. 90:

For **AWC** and **AWN** wall-mounted units, you must first remove the bodywork or the front blanking panel. Finally, for **AHN/AHC** ceiling-mounted units, follow the procedure below:

Condensate drain pan removal - **AHC / AHN** units

1. On **AHC** unit, remove cabinet (see instructions in section "Unit installation/Cabinet removal").
2. Remove drain pipe.
3. Take off auxiliary drain pan, after removing the 2 fixing screws.
4. Remove the fixing screws of the main drain pan. Pull downward the side opposite to the condensate outlet side, then take out the main drain pan by releasing the condensate outlet tube from its location.
5. Before re-installing, make an internal cleaning of the drain pans.
6. To reassemble the condensate drain pans, do as above in the reverse way.



Check the good condition of the gasket ensuring the tightness between the auxiliary drain pan and the wall of the unit casing.

COILS

The clean state of the coils is a positive factor for proper efficiency of the unit.

To avoid mouldiness of coils caused by an accumulation of fine dusts, it is recommended to clean them frequently.

If necessary comb the coil fins with an appropriate tool.

On the ceiling **AHC / AHN** (10-80-90) unit, to have direct access to the coil, it is necessary to remove the condensate drain pans.

FAN MOTOR ASSEMBLY

There is no particular maintenance on fan and motor assembly. All fan coil units utilize permanently lubricated fan motor bearings.

However during periodic maintenance, check that fan wheel does not touch the housing and adjust, if necessary, clearance.

If fan motor overload protection open, wait for automatic overload reset and try to determine the cause.

On the ceiling **AHC / AHN** (10-80-90) unit, to have direct access to the fan and motor assembly, it is necessary to remove the access panel.

Take care

It is not the manufacturer's policy to make recommendations in terms of water treatment (please contact a specialised water treatment company).

However, given the critical nature of this subject, particular care should be taken to ensure that, if treatment is required, it works effectively.

Using untreated or unsuitable water leads to excessive clogging inside the coil tubes (earth and mud deposits, corrosion, etc.) with major consequences on the thermal efficiency of the unit and irreversible damage to the equipment.

The manufacturer and its representative decline all responsibility in the event of untreated or incorrectly treated water being used.

IN CASE OF WARRANTY - MATERIAL RETURN PROCEDURE

Material must not be returned without permission of our After Sales Department.

To return the material, contact your nearest sales office and ask for a "return voucher". The return voucher shall be sent with the returned material and shall contain all necessary information concerning the problem encountered.

The return of the part is not an order for replacement. Therefore, a purchase order must be entered through your nearest distributor or regional sales office. The order should include part name, part number, model number and serial number of the unit involved.

Following our personal inspection of the returned part, and if it is determined that the failure is due to faulty material or workmanship, and in warranty, credit will be issued on customer's purchase order. All parts shall be returned to our factory, transportation charges prepaid.

ORDERING SERVICE AND SPARE PARTS ORDER

The part number, the order confirmation and the unit serial number indicated on the name plate must be provided whenever service works or spare parts are ordered.

For any spare part order, indicate the date of unit installation and date of failure. Use the part number provided by our service spare parts, if it not available, provide full description of the part required.

CAUTION



**BEFORE CARRYING OUT ANY OPERATION ON THE EQUIPMENT,
CHECK THAT THE ELECTRICAL POWER SUPPLY IS SWITCHED OFF
AND THAT IT CANNOT BE SWITCHED ON INADVERTENTLY.**

**APPENDIX
ANNEXE
ANLAGE
ALLEGATO
ANEXO**

APPENDIX

DIMENSIONS	III	WIRING DIAGRAM	VI
AWC/AHC.....	III	SE3530 10 - 90 CMV.....	VII
AWN.....	IV	SE3531 10 - 90 CMV/TBV.....	VIII
AHN.....	IV	SE3532 10 - 90 CMV/TBV1	IX
VIEW OF MAIN COMPONENTS - AWC FAN COIL UNIT..	V	SE3533 10 - 90 CMV/TBMV1.....	X
		SE3534 10 - 90 CMV/TBV.....	XI
		SE3535 10 - 90 AQUANET	XII
		SE3585 70 - 90 AQUANET + ELECTRIC HEATING	XIII
		SE3537 10 - 90	XIV
		MODEL NOMENCLATURE	XVIII

ANNEXE

DIMENSIONS	III	SCHEMAS ELECTRIQUES	VI
AWC/AHC.....	III	SE3530 10 - 90 CMV.....	VII
AWN.....	IV	SE3531 10 - 90 CMV/TBV.....	VIII
AHN.....	IV	SE3532 10 - 90 CMV/TBV1	IX
VUE DES PRINCIPAUX COMPOSANTS - MODELE AWC ...	V	SE3533 10 - 90 CMV/TBMV1.....	X
		SE3534 10 - 90 CMV/TBV.....	XI
		SE3535 10 - 90 AQUANET	XII
		SE3585 70 - 90 AQUANET + CHAUFFAGES ELECTRIQUES.	XIII
		SE3537 10 - 90	XIV
		NOMENCLATURE DES APPAREILS	XVIII

ANLAGE

ABMESSUNGEN	III	STROMLAUFLANS	VI
AWC/AHC.....	III	SE3530 10 - 90 CMV.....	VII
AWN.....	IV	SE3531 10 - 90 CMV/TBV.....	VIII
AHN.....	IV	SE3532 10 - 90 CMV/TBV1	IX
ÜBERSICHT - AWC-MODELL.....	V	SE3533 10 - 90 CMV/TBMV1.....	X
		SE3534 10 - 90 CMV/TBV.....	XI
		SE3535 10 - 90 AQUANET	XII
		SE3585 70 - 90 AQUANET + ELEKTROHEIZUNG	XIII
		SE3537 10 - 90	XIV
		BEZEICHNUNG DER GERÄTE	XVIII

ALLEGATO

DIMENSIONI.....	III	SCHEMA ELETTRICO	VI
AWC/AHC.....	III	SE3530 10 - 90 CMV.....	VII
AWN.....	IV	SE3531 10 - 90 CMV/TBV.....	VIII
AHN.....	IV	SE3532 10 - 90 CMV/TBV1	IX
COMPONENTI PRINCIPALE – UNITÀ VERTICALE MODELLO AWC	V	SE3533 10 - 90 CMV/TBMV1.....	X
		SE3534 10 - 90 CMV/TBV.....	XI
		SE3535 10 - 90 AQUANET	XII
		SE3585 70 - 90 AQUANET + RISCALDAMENTO ELETTRICO.	XIII
		SE3537 10 - 90	XIV
		NOMENCLATURA – DESCRIZIONE DEGLI APPARECCHI ...	XVIII

ANEXO

DIMENSIONES	III	ESQUEMA ELECTRICO.....	VI
AWC/AHC.....	III	SE3530 10 - 90 CMV.....	VII
AWN.....	IV	SE3531 10 - 90 CMV/TBV.....	VIII
AHN.....	IV	SE3532 10 - 90 CMV/TBV1	IX
VISTA DE LOS COMPONENTES PRINCIPALES - UNIDAD FAN COIL AWC.....	V	SE3533 10 - 90 CMV/TBMV1.....	X
		SE3534 10 - 90 CMV/TBV.....	XI
		SE3535 10 - 90 AQUANET	XII
		SE3585 70 - 90 AQUANET + CALEFACCION ELECTRICA ..	XIII
		SE3537 10 - 90	XIV
		NOMENCLATURA.....	XVIII

DIMENSIONS



DIMENSIONS

ABMESSUNGEN


DIMENSIONI

DIMENSIONES

AWC/AHC




Bac auxiliaire et pieds en option



A : auxiliary coil water inlet
 B : auxiliary coil water outlet
 C : main coil water inlet
 D : main coil water outlet


A : entrée eau batterie auxiliaire
 B : sortie eau batterie auxiliaire
 C : entrée eau batterie principale
 D : sortie eau batterie principale




	A	B	C	D	E	F	G	H	I	J
20	768	478	408	390	256	236	52	95	141	183
30	953	478	408	390	256	236	52	95	141	183
40	1138	478	408	390	256	236	52	95	141	183
50	1323	478	408	390	256	236	52	95	141	183
60	1508	478	408	390	256	236	52	95	141	183
70	1323	578	506	492	289	233	41	88	145	172
80	1508	578	500	489	245	234	40	83	143	186
90	1693	578	500	489	245	234	40	83	143	186

APPENDIX / ANNEXE / ANLAGE / ALLEGATO / ANEXO

AWN




A : auxiliary coil water inlet
 B : auxiliary coil water outlet
 C : main coil water inlet
 D : main coil water outlet
 A : entrée eau batterie auxiliaire
 B : sortie eau batterie auxiliaire
 C : entrée eau batterie principale
 D : sortie eau batterie principale






	A	B	C	D	E	F	G	H	I	J
10	370	430	406	390	255	238	54	95	141	182
20	510	430	408	390	256	236	52	95	141	183
30	695	430	408	390	256	236	52	95	141	183
40	880	430	408	390	256	236	52	95	141	183
50	1065	430	408	390	256	236	52	95	141	183
60	1250	430	408	390	256	236	52	95	141	183
70	1065	530	506	492	289	233	41	88	145	172
80	1250	530	500	489	245	234	40	83	143	186
90	1435	530	500	489	245	234	40	83	143	186

AHN



A : auxiliary coil water inlet
 B : auxiliary coil water outlet
 C : main coil water inlet
 D : main coil water outlet



Caution ! Do not fix duct to edge of condensate drain pan, in order to allow pan removal.

Attention ! Ne pas fixer la gaine sur le rebord du bac à condensats (démontage du bac compromis)



	A	B	C	D	E	F	G	H	I	J	K	L	M	N
10	370	430	406	390	255	238	54	95	141	182	583	122	30	68
20	510	430	408	390	256	236	52	95	141	183	723	122	30	68
30	695	430	408	390	256	236	52	95	141	183	908	122	30	68
40	880	430	408	390	256	236	52	95	141	183	1093	122	30	68
50	1065	430	408	390	256	236	52	95	141	183	1278	122	30	68
60	1250	430	408	390	256	236	52	95	141	183	1463	122	30	68
70	1065	530	506	492	289	233	41	88	145	172	1278	123	32	65
80	1250	530	500	489	245	234	40	83	143	186	1463	123	32	65
90	1435	530	500	489	245	234	40	83	143	186	1648	123	32	65

A : auxiliary coil water inlet

B : auxiliary coil water outlet

C : main coil water inlet

D : main coil water outlet

A : entrée eau batterie auxiliaire

B : sortie eau batterie auxiliaire

C : entrée eau batterie principale

D : sortie eau batterie principale


VIEW OF MAIN COMPONENTS - AWC FAN COIL UNIT

VUE DES PRINCIPAUX COMPOSANTS - MODÈLE AWC

UBERSICHT - AWC-MODELL

COMPONENTI PRINCIPALE – UNITÀ VERTICALE MODELLO AWC

VISTA DE LOS COMPONENTES PRINCIPALES - UNIDAD FAN COIL AWC



REP	GB	F	D	I	E
1	Coil	Batterie	Register	Batteria	Batería
2	Discharge grille	Grille de soufflage	Ausblasgitter	Griglia di mandata	Rejilla de descarga
3	Fan speed selector under access cover	Commutateur de vitesses sous la trappe d'accès	Drehzahl-Wahlschalter unter der Zugang-Falltür	Commutatore di velocità sotto la trappola di accesso	Selector de velocidades bajo la tapa de acceso
4	Cabinet	Habilage	Verkleidung	Carrozzeria	Envolvente
5	Fan motor	Moteur du ventilateur	Gebläsemotor	Motore del ventilatore	Motor del ventilador
6	Condensate drain pan	Bac à condensats isolé	Kondensatauffangwanne	Bacinella di raccolta condensa	Bandeja de drenaje de condensados
7	Fan	Ventilateur	Ventilator	Ventilatore	Turbina del ventilador
8	Air filter	Filtre à air	Luftfilter	Filtro aria	Filtro
9	Condensate drain pipe	Tuyau d'évacuation des condensats	Kondensatableitung	Flessibile di drenaggio condensa	Tubería de drenaje de condensados
10	Coil headers	Collecteurs de raccordement	Anschlußsampler	Collettori di batteria	Tomas de la batería
11	Mounting brackets	Pattes de fixation avec trou boutonnière	Halterungen mit Langloch	Bande con asole di fissaggio	Soportes de montaje

WIRING DIAGRAM

SCHEMAS ELECTRIQUES

STROMLAUFPLANS

SCHEMA ELETTRICO

ESQUEMA ELECTRICO

TAKE CARE!

These wiring diagrams are correct at the time of publication. Manufacturing changes can lead to modifications. Always refer to the diagram supplied with the product.

ATTENTION

Ces schémas sont corrects au moment de la publication. Les variantes en fabrication peuvent entraîner des modifications. Reportez-vous toujours au schéma livré avec le produit.

ACHTUNG!

Diese Stromlaufpläne sind zum Zeitpunkt der Veröffentlichung gültig. In Herstellung befindliche Varianten können Änderungen mit sich bringen. In jedem Fall den mit dem Produkt gelieferten Stromlaufplan hinzuziehen.

ATTENZIONE !

Questi schemi sono corretti al momento della pubblicazione. Le varianti apportate nel corso della fabbricazione possono comportare modifiche. Far sempre riferimento allo schema fornito con il prodotto.

ATENCIÓN !

Esto esquemas son correctos en el momento de la publicación. Pero las variantes en la fabricación pueden ser motivo de modificaciones. Remítase siempre al esquema entregado con el producto.

**POWER SUPPLY MUST BE SWITCHED OFF BEFORE STARTING TO
WORK IN THE ELECTRIC CONTROL BOXES!**

**MISE HORS TENSION OBLIGATOIRE AVANT TOUTE INTERVENTION
DANS LES BOITIERS ELECTRIQUES.**

**VOR JEDEM EINGRIFF AN DEN ANSCHLUßKÄSTEN UNBEDINGT
DAS GERÄT ABSCHALTEN!**


**PRIMA DI OGNI INTERVENTO SULLE CASSETTE ELETTRICHE
ESCLUDERE TASSATIVAMENTE L'ALIMENTAZIONE !**

**PUESTA FUERA DE TNESIÓN OBLIGATORIA ANTES DE CUALQUIER
INTERVENCIÓN EN LAS CAJAS ELÉCTRICAS!**



GMV GROUPE MOTEUR VENTILATEUR
V5 à V1 PETITE à GRANDE VITESSE
CMV COMMUTATEUR DE VITESSE
M BORNIER DE RACCORDEMENT

**VENTILO-CONNECTEUR
10 A 90 CMV**



GMV GROUPE MOTEUR VENTILATOR
V5-V1 MINIMA-MASSIMA VELOCITA
CMV COMMUTATORE DI VELACITA
M MORSETTI SCATOLA ELECT.

OPZIONI

- ECH RESISTENCIA CALEFACCION
- FCA TERMOSTATO AUTO
- FCM SEGURIDAD MANUAL
- VF VALVULA ESTATE/INVERNO
- VCH VALVULA INVERNO (4 tubo)
- F PROTECCION GENERAL

GMV MOTOR VENTILACION
V5-V1 BAJA-ALTA VELOCIDAD
CMV INTERRUPTOR DE VELOCIDAD
M BORNERA DE CONEXION

Opciones

- ECH RESISTENCIA CALEFACCION
- FCA TERMOSTATO AUTO
- FCM SEGURIDAD MANUAL
- VF VALVULA FRIO/CAO
- VCH VALVULA CALO (4 tubos)
- F PROTECCION GENERAL

GMV VENTILATORMOTOREINHEIT
V5-V1 NIEDRIGE-HOCH DREHZAHLEN
CMV GE SCHWINDIGKEITS SCHALTER
M KLEMMLEISTE

OPTIONEN

- ECH HEIZUNGSMIDERSTAND
- FCA UBERHITZUNGSSCHUTZ
- FCM HANDÜBERHEIZUNGSSCHIEBER
- VF KALTWASSERSCHIEBER/WÄRMWASSERSCHIEBER
- VCH WÄRMWASSERSCHIEBER (4 rohren)
- F ALLGENEIMER SCHUTZ

OPTIONS

- ECH ELEMENT(S) CHAUFFANT(S)
- FCM SECURITE MANUELLE
- FCA SECURITE AUTOMATIQUE
- VF MOTEUR DE VANNE-EAU FROIDE/CHAUD(E)
- VCH MOTEUR DE VANNE-EAU CHAIDE(4T)
- F PROTECTION GENERALE

TAILLE	V5	V4	V3	V2	V1
10/20	0G	RD	VT	GY	BK
30/60/80/90	RD	BN	VT	GY	BK
40/50	0G	RD	BN	VT	BK
70	RD	BN	VT	BK	IWH

BK	NOIR	BLACK	NEGRO	SCHWARTZ	NERO
OR	ORANGE	ORANGE	NARANJA	ARANCIONE	ARANCIO
WH	BLANC	WHITE	BLANCO	BIANCO	BIANCO
RD	ROUGE	RED	ROJO	ROJO	ROJO
BU	BLEU	BLUE	AZUL	BLAU	AZUL
GNYE	VERT/JA.	GREEN/YELL.	VERDE/AM.	GRANAT/G.	VERDE/AM.
VT	VIOLET	PURPLE	VIOLETT	VIOLETT	VIOLETT
BN	BROWN	BROWN	MARRONE	MARRONE	MARRONE
GY	GRIS	GREY	GRAU	GRIGIO	GRIGIO

CODE : 399923
230V~ 50 Hz
SE 3530

APPENDIX / ANNEXE / ANLAGE / ALLEGATO / ANEXO

SE3531 10 - 90 CMV/TBV

GMV GROUPE MOTEUR VENTILATEUR
V5 à V1 PETITE à GRANDE VITESSE
CMV COMMUTATEUR DE VITESSE
TH THERMOSTAT A BULBE
H BORNIER DE RACCORDEMENT

OPTIONS

V MOTEUR DE VANNE-EAU FROIDE OU CHAUE
SW THERMOSTAT CHANGE-OVER MECHANIQUE
F PROTECTION GENERALE


	TAILLE	V5	V4	V3	V2	V1
10/20	0G	RD	VT	GY	BK	
30/60/80/90	RD	BN	VT	GY	BK	
40/50	0G	RD	BN	VT	BK	
70	RD	BN	VT	BK	KH	

BK	NOIR	BLACK	NEGRO	SCHMIDT	NERO
OR	ORANGE	ORANGE	NARANJA	ARANCIONE	ARANCIO
WH	BLANC	WHITE	BLANCO	BIANCO	BIANCO
RD	ROUGE	RED	ROSSO	ROJO	ROJO
BU	BLEU	BLUE	BLAU	BLAU	AZUL
GNYE	VERT/JA.	GREEN/YELL.	GRANATO/G.	VERDE/AM.	
VT	VIOLET	PURPLE	VIOLA	VIOLETT	
BN	BRUN	BROWN	MARRON	MARRONE	
GY	GRIS	GREY	GRIS	GRIGIO	

CODE : 399924
230V ~ 50 Hz

SE 3531

VENTILO-CONVECTEUR
10 A 90 CMV-TBV



GMV MOTOR VENTILATOR
V5-V1 BAJA-ALTA VELOCIDAD
CMV INTERRUPTOR DE VELOCIDAD
TH TERMOSTATO
H BORNERA DE CONEXION
OPCIONES

V VALVULA FRIO/CALEO
SW TERMOSTATO CHANGE-OVER
F PROTECCION GENERAL
OPZIONI

V COOLING OR HEATING VALVE
SW CHANGE-OVER THERMOSTAT
F GENERAL PROTECTION
OPZIONI

GMV VENTILATORMOTORE INHEIT
V5-V1 NIEDRIGE-HOCH DREHZAHLEN
CMV GE SCHWINDIGKEITS SCHALTER
TH THERMOSTAT
H KLEMMLISTE
OPTIONEN

V KALTWAESSERSCHIEBER/WARMWAESSERSCHIEBER
SW THERMOSTATE CHANGE-OVER
F ALLGENETIMER SCHUTZ
OPTIONEN


**VENTILO-CONVECTEUR
10 A 90 CMV-TBV1**

GMV GROUPE MOTEUR VENTILATEUR
V5 à V1 PETITE à GRANDE VITESSE
CMV COMMUTATEUR DE VITESSE
TH THERMOSTAT A BULBE

M BORNIER DE RACCORDEMENT

OPTIONS

V MOTEUR DE VANNE-EAU FROIDE OU CHAUE
SH THERMOSTAT CHANGE-OVER MECHANIQUE
F PROTECTION GENERALE



TAILLE	V5	V4	V3	V2	V1
10/20	OG	RD	VT	GY	BK
30/60/80/90	RD	BN	VT	GY	BK
40/50	OG	RD	BN	VT	BK
70	RD	BN	VT	BK	WH

BK	NOIR	BLACK	NEGRO	SCHWARTZ	NERO
OR	ORANGE	ORANGE	NAJANJA	ORANGE	ARANCIONE
WH	WHITE	WHITE	BLANCO	WEISS	BIANCO
RD	RED	RED	ROSSO	ROT	ROJO
BU	BLEU	BLUE	BLU	BLAU	AZUL
GNYE	VERT/JA.	GREEN/YELL.	GIALLO/V.GRAN/G.	VERDE/AM.	VERDE/AM.
VT	PURPLE	PURPLE	VIOLET	VIOLETT	VIOLETA
BN	BROWN	BROWN	BRUN	BRUN	MARRONE
GY	GRIS	GREY	GRAU	GRIS	GRIGIO

GMV VENTILATOR MOTORREINHEIT
V5-V1 NIEDRIGE-HOCH DREIZAHL
CMV SCHWINDIGKEITSSCHALTER
TH THERMOSTAT
M KLEMLEISTE

OPTIONS

V KALTWAERSCHIEBER/WARMWAERSCHIEBER
SH THERMOSTATE CHANGE-OVER
F ALLGENEIMER SCHUTZ

CODE : 399925

230V ~ 50 Hz
SE 3532

GMV GROUPE MOTO VENTILACION
V5-V1 MINIMA-MAXIMA VELOCIDAD
CMV INTERRUPTOR DE VELOCIDAD
TH TERMOSTATO
M MORSETTI SCATOLA ELECT.

Opciones

V VALVULA FRIO/CALEO
SH TERMOSTATO CHANGE-OVER
F PROTECCION GENERAL

V VALVOLA ESTATE/INVERNO
SH TERMOSTATO CHANGE-OVER
F PROTEZIONE GENERALE

230V ~ 50 Hz
SE 3532

**VENTILO-CONVECTEUR
10 A 90 CMV-TBMV1**

GMV GROUPE MOTEUR VENTILATEUR
V5 à V1 PETITE à GRANDE VITESSE
CMV COMMUTATEUR DE VITESSE
TH THERMOSTAT à BULBE
SC INVERSEUR FROID/CHAUD
H BORNIER DE RACCORDEMENT


OPTIONS

ECH ELEMENT(S) CHAUFFANT(S)
FCM SECURITE MANUELLE
FCA SECURITE AUTOMATIQUE
VF MOTEUR DE VANNE-EAU FROIDE/CHAUD
VCH MOTEUR DE VANNE-EAU CHAUEDE(4t)
F PROTECTION GENERALE

OPTIONS

TAILLE	V5	V4	V3	V2	V1
10/20	OG	RD	VT	GY	BK
30/60/80/90	RD	BN	VT	GY	BK
40/50	OG	RD	BN	VT	BK
70	RD	BN	VT	BK	WH

BK	NOIR	BLACK	NEGRO	SCHWARTZ	NERO
OR	ORANGE	NAJANJA	ORANGE	ARANCIONE	ARANCIO
WH	BLANC	WHITE	WEISS	BIANCO	BIANCO
RD	ROUGE	RED	ROT	ROJO	ROJO
BU	BLEU	BLUE	BLAU	AZUL	AZUL
GNYE	VERT/JA.	GREEN/YELL.	GRIALLO/V.GRIN/G.	VERDE/AM.	VERDE/AM.
VT	VIOLET	PURPLE	VIOLETT	VIOLETA	VIOLETA
BN	BRUN	BROWN	MARRON	BRAUN	MARRONE
GY	GRIS	GREY	GRIS	GRAU	GRIGIO



GMV GROUPE MOTEUR VENTILATOR
V5-V1 MINIMA-MASSIMA VELOCITA
CMV COMMUTATORE DI VELACITA
TH TERMOSTATO
SC INVERTITORE CALDO/FREDDO
H MORSETTI SCATOLA ELECT.

OPZIONI

ECH RESIST. RISCALDAMENTO
FCM TERMOSTATO AUTOMATICO
FCA SECUREZZA MANUALE
FCA SECUREZZA AUTOMATICA
VF VALVOLA ESTATE/INVERNO
VCH VALVOLA INVERNO (4 tubi)
F PROTEZIONE GENERALE

GMV MOTOR VENTILACION
V5-V1 BAJA-ALTA VELOCIDAD
CMV INTERRUPTOR DE VELOCIDAD
TH TERMOSTATO
SC INVERSOR CALOR/FRIO
H BORNERA DE CONEXION

Opciones

ECH RESISTENCIA CALEFACCION
FCA TERMOSTATO AUTO
FCA SEGURIDAD MANUAL
FCA SEGURIDAD AUTOMATICA
VF VALVULA FRIO/CALEO
VCH VALVULA CALO (4 tubos)
F PROTECCION GENERAL

GMV VENTILATORMOTOREINHEIT
V5-V1 NIEDRIGE-HOHE DREHZAHLEN
CMV GE SCHWINDIGKEITSSCHALTER
TH THERMOSTAT
SC UNSCHALTER HEIZUNG/KUHLUNG
H KLEMMLEISTE

OPTIONEN


ECH HEIZUNGSDERSTAND
FCM UBERHITZUNGSSCHUTZ
FCA GE SCHWINDIGKEITSSCHALTER
VF KALT WASSERSCHALTER/WARMWASSERSCHIEBER
VCH WARMWASSERSCHIEBER (4 rohren)
F ALLGENIMER SCHUTZ

CODE : 399926
230V ~ 50 Hz
SE 3533

GMV GROUPE MOTEUR VENTILATEUR
V5 à V1 PETITE à GRANDE VITESSE
CMV COMMUTATEUR DE VITESSE
TH THERMOSTAT A BULBE
SC INVERSEUR FROID/CHAUD

VENTILO-CONVECTEUR
10 A 90 CMV-TBMV

AVEC RELAIS DE CHAUFFAGE/WITH HEATER RELAY



OPTIONS

- ECH ELEMENT(S) CHAUFFANT(S)
- FCA SECURITE AUTOMATIQUE
- FCM SECURITE MANUELLE
- VF MOTEUR DE VANNE-EAU FROIDE/CHAUD
- VCH MOTEUR DE VANNE-EAU CHAUD(4T)
- F PROTECTION GENERALE

	TAILLE		V5	V4	V3	V2	V1
	10/20	30/60/80/90					
	40/50						
	70						

BK	NOIR	BLACK	NEGRO	SCHWARZ	NERO
OR	ORANGE	WHITE	BLANCO	ARANCIONE	BIANCO
HH	BLANC	RED	HEISS	ROJO	ROJO
RD	ROUGE	BLEU	BLAU	AZUL	AZUL
BU	BLEU	GREEN/YELL.	GRUN/GELB	VERDE/AM.	VERDE/AM.
GRY	GRYE	PURPLE	VIOLA	VIOLETT	VIOLETA
VT	VT	BRUN	MARRON	BRAUN	MARRONE
BN	BN	BROWN	GRIS	GRAU	GRIGIO
GY	GY	GREY	GRIS	GRIS	GRIS

GMV VENTILATOR/MOTOR/EINHEIT
V5-V1 NIEDRIGE-HOHE DREHZAHN
CMV GESENKT/INDIGEITSSCHALTER
TH THERMOSTAT
SC UMSCHALTER HEIZUNG/KÜHLUNG
M KLEMMLEISTE

OPTIONEN

CODE : 399927
230V ~ 50 Hz
SE 3534

GMV MOTOR VENTILATOR
V5-V1 MINIMA-MASSIMA VELOCIDAD
CMV INTERRUPTOR DE VELOCIDAD
TH THERMOSTATO
SC INVERSOR CALOR/FRÍO
M BORNERA DE CONEXION

OPCIONES

ECH RESISTENCIA CALEFACCION
FCA TERMOSTATO AUTO
FCM SEGURIDAD MANUAL
VF VALVULA ESTATE/INVERNO
VCH VALVULA INVERNO (4 tubos)
F PROTECCION GENERAL

GMV GROUPE MOTEUR VENTILATEUR
V5-V1 MINIMA-MASSIMA VELOCITA
CMV COMMUTATORE DI VELOCITA
TH THERMOSTATO
SC INVERTTORE CALDO/FREDDO
M MORSETTI SCATOLA ELET.

OPCIONES

ECH HEIZUNG/WIDERSTAND
FCA UBERHITZUNGSSCHUTZ
FCM HANDÜBERHITZUNGSSCHUTZ
VF KALTWASSERSCHIEBER/WARMWASSERSCHIEBER
VCH WARMWASSERSCHIEBER (4 röhren)
F ALLGEMEINER SCHUTZ

GMV FAN MOTOR
V5-V1 LOW-MAX SPEED
CMV SWITCH SPEED
TH BULBE THERMOSTAT
SC HEATING COOLING SELECT
M TERMINAL STRIP

OPCIONES

ECH RESIST. RISCALDAMENTO
FCA TERMOSTATO AUTOMATICA
FCM SEGUREZZA MANUALE
VF VALVOLA ESTATE/INVERNO
VCH VALVOLA INVERNO (4 pipe)
F GENERAL PROTECTION



APPENDIX / ANNEXE / ANLAGE / ALLEGATO / ANEXO

SE3535 10 - 90 AQUANET

AQUAFAN AQUANET

PCB	10/20	10/20	V5	V4	V3	V2	V1
30/60/80/90	RD	VT	GY	BK			
40/50	OG	RD	BN	VT	GY	BK	
70	RD	BN	VT	BK			

PCB REGULATEUR AQUANET
SA SONDE REPRÉSENTE D'AIR
AUTRES UNITES 4 →
AUTRES UNITES 2 →
OTRAS UNIDADES 4 →
ANDERE EINHEITEN 2 →




GMV FAN MOTOR	VF COOLING VALVE	VF COOLING VALVE
C CONDENSATOR	VCF HEATING VALVE	VCF HEATING VALVE
PCB AQUANET CONTROL BOARD	R1 HEATING RESISTOR-STAGE 1	R1 HEATING RESISTOR-STAGE 1
SA AIR TEMPERATURE SENSOR	R2 HEATING RESISTOR-STAGE 2	R2 HEATING RESISTOR-STAGE 2
OPTIONS	FCA AUTO THERMOSTAT SAFETY	FCA AUTO THERMOSTAT SAFETY
	FCH MANUEL THERMOSTAT SAFETY	FCH MANUEL THERMOSTAT SAFETY
	KR HEATER RELAY >1500Ω	KR HEATER RELAY >1500Ω
	HPT WATER SENSOR	HPT WATER SENSOR
	F GENERAL PROTECTION	F GENERAL PROTECTION
	NTU INTERFACE COMMUNICATION AS BUS	NTU INTERFACE COMMUNICATION AS BUS
	NO FITTED	NO FITTED
	SU UNOCCUPIED CONTACT	SU UNOCCUPIED CONTACT
	SF WINDOW CONTACT	SF WINDOW CONTACT
GMV GROUPE MOTEUR VENTILATEUR	GMV MOTOR VENTILACION	GMV MOTOR VENTILACION
C CONDENSATEUR	C CONDENSADOR	C CONDENSADOR
PCB REGULATEUR AQUANET	PCB REGULACION AQUANET	PCB REGULACION AQUANET
SA SONDE RETOURN	SA SONDA RETORNO	SA SONDA RETORNO
OPTIONS	OPTIONAL	OPTIONAL
	VF VALVULA FRIO	VF VALVULA FRIO
	VCF VALVULA CALOR	VCF VALVULA CALOR
	R1 ELECTRORISCALADORE-1 1500Ω	R1 RESIST.CALEFACCION-1 NIVEL
	R2 ELECTRORISCALADORE-2 1500Ω	R2 RESIST.CALEFACCION-2 NIVEL
	FCA SEGUREZZA AUTOMATICO	FCA SEGUREZZA AUTOMATICO
	FCH SEGUREZZA MANUALE	FCH SEGUREZZA MANUALE
	KR RESISTANCIA 1500Ω	KR RESISTANCIA 1500Ω
	NPT SONDA DI TEMPERATURA ACQUA	NPT SONDA DI TEMPERATURA ACQUA
	F PROTEZIONE GENERALE	F PROTEZIONE GENERALE
	NTU COLLEGAMENTO PER SCHEDA	NTU COLLEGAMENTO PER SCHEDA
	AUXILIARIA	AUXILIARIA
	NO FORNITA	NO FORNITA
	SU Interruttore assente	SU Interruttore assente
	SF CONTRACCIO DE VENTANA	SF CONTRACCIO DE VENTANA
	NO SUMINISTRADO	NO SUMINISTRADO
GMV VENTILATOR/MOTORREINHOLD	GM VENTILATOR/MOTORREINHOLD	GM VENTILATOR/MOTORREINHOLD
C KONDENSATOR	C KONDENSATOR	C KONDENSATOR
PCB BEDIENTPLATINE AQUANET	PCB BEDIENTPLATINE AQUANET	PCB BEDIENTPLATINE AQUANET
SA RUCKHOLLSONDE	SA RUCKHOLLSONDE	SA RUCKHOLFSONDE
ZUBEHOR	ZUBEHOR	ZUBEHOR
	VF KALTWASSER MAGNETVENTIL	VF KALTWASSER MAGNETVENTIL
	VCF WÄRMER TEMPERATURESONDE	VCF WÄRMER TEMPERATURESONDE
	F SICHERUNG	F SICHERUNG
	PCB ZUSÄTZRÄTTE FÜR SPEZIFISCHE	PCB ZUSÄTZRÄTTE FÜR SPEZIFISCHE
	BRÜSELTISCHEN	BRÜSELTISCHEN
	SF FENSTER	SF FENSTER
	CABLAGE CLIENT	CABLAGE CLIENT
	230V ~ 50 Hz ~	230V ~ 50 Hz ~
	SE 3535A	SE 3535A
	CODE 399928	CODE 399928

APPENDIX / ANNEXE / ANLAGE / ALLEGATO / ANEXO


SE3585 70 - 90 AQUANET + ELECTRIC HEATING

AQUAFAN 2T2F AQUANET



APPENDIX / ANNEXE / ANLAGE / ALLEGATO / ANEXO

SE3537 10 - 90




APPENDIX / ANEXE / ANLAGE / ALLEGATO / ANEXO


	2T	4T					
GB	2-PIPE COILS	4-PIPE COILS	COOLING	HEATING	LOW SPEED	MEDIUM SPEED	HIGH SPEED
F	BATTERIES 2 TUBES	BATTERIES 4 TUBES	FROID	CHAUD	PETITE VITESSE	VITESSE MOYENNE	GRANDE VITESSE
D	BATTERIEN 2 ROHREN	BATTERIEN 4 ROHREN	KÜHLUNG	HEIZUNG	KLEINE GE SCHWINDIGKEIT	MITTLERE GE SCHWINDIGKEIT	HOHE GE SCHWINDIGKEIT
I	BATTERIE 2 TUBI	BATTERIE 4 TUBI	FREDDO	RISCALDO	BASSA VELOCITÀ	VELOCITÀ MEDIA	ALTA VELOCITÀ
E	BATERÍAS 2 TUBOS	BATERÍAS 4 TUBOS	FRIO	CALOR	VELOCIDAD BAJA	VELOCIDAD MEDIA	VELOCIDAD ALTA

			SCH	SW
GB	ELECTRIC HEATING	CONTROL VALVE	CHANGE OVER (TAE 20)	CHANGE OVER (TRM-FA TRM-VP)
F	CHAUFFAGE ELECTRIQUE	VANNE DE REGULATION	CHANGE OVER (TAE 20)	CHANGE OVER (TRM-FA TRM-VP)
D	ELEKTROHEIZUNG	REGELVENTIL	CHANGE OVER (TAE 20)	CHANGE OVER (TRM-FA TRM-VP)
I	RISCALDAMENTO ELETTRICO	VALVOLA DI REGOLAZIONE	CHANGE OVER (TAE 20)	CHANGE OVER (TRM-FA TRM-VP)
E	CALEFACCION ELECTRICA	VÁLVULA REGULADORA	CHANGE OVER (TAE 20)	CHANGE OVER (TRM-FA TRM-VP)


2T + (+) + + SCH




2T + () +



2T + (+) + SCH




2T + ()




APPENDIX / ANNEXE / ANLAGE / ALLEGATO / ANEXO


2T+ (H)




4T+ (H + H)




2T+ (H) + //




2T+ (H + H) + SW




2T+ (H + H)




2T+ (H)



2T+ (H)




4T+ (H + H)




APPENDIX / ANEXE / ANLAGE / ALLEGATO / ANEXO


2T+ ()+




2T+ (img alt="thermostat icon") + SW




2T+ (img alt="thermostat icon") +




2T+ (img alt="thermostat icon")




2T+ ()



2T+ (img alt="thermostat icon") +



4T+ (img alt="thermostat icon") +



MODEL NOMENCLATURE

NOMENCLATURE DES APPAREILS

BEZEICHNUNG DER GERÄTE

NOMENCLATURA – DESCRIZIONE DEGLI APPARECCHI

NOMENCLATURA

REP.	GB	F	D	E
	MODEL	TAILLES	GRÖSSEN	MISURE
A10	MODEL 10	MODELE 10	MODELL 10	MODELLO 10
A20	MODEL 20	MODELE 20	MODELL 20	MODELLO 20
A30	MODEL 30	MODELE 30	MODELL 30	MODELLO 30
A40	MODEL 40	MODELE 40	MODELL 40	MODELLO 40
A50	MODEL 50	MODELE 50	MODELL 50	MODELLO 50
A60	MODEL 60	MODELE 60	MODELL 60	MODELLO 60
A70	MODEL 70	MODELE 70	MODELL 70	MODELLO 70
A80	MODEL 80	MODELE 80	MODELL 80	MODELLO 80
A90	MODEL 90	MODELE 90	MODELL 90	MODELLO 90
	MOUNTING	MONTAGE	MONTAGGIO	MONTAJE
W	CONSOLE MOUNTING	MONTAGE ALLEGÉ MURAL	VANDMONTAGE MIT STÜTZMAUER	MONTAJE ALFIEZAR MURAL
H	HORIZONTAL CEILING MOUNTING	MONTAGE PIAFONNIER HORIZONTAL	DECKENMONTAGE HORIZONTAL	MONTAJE DE TECHO HORIZONTAL
	WITH CASING / WITHOUT CASING	HABILLAGE / MODELE NU	GEHÄUSE / MODELL OHNE VERKLEIDUNG	RIVESTIMENTO / MODELLO NON RIVESTITO
N	MODEL WITHOUT CASING	MODELE NU	MODELL OHNE VERKLEIDUNG	MODELLO NON RIVESTITO
C	MODEL WITH CASING	MODELE CARROSSE	MODELL MIT VERKLEIDUNG	MODELLO CAROZZATO
	BRAND	MARQUE COMMERCIALE	HANDELSMARKE	MARCA COMERCIAL
MARQUE	INDICATES BRAND	INDIQUE LA MARQUE COMMERCIALE	ZEIGT DIE HANDELSMARKE AN COMMERCIALE	INDICA LA MARCA COMERCIAL
\$	NO BRAND	SANS MARQUE	OHNE MARKE	SENZA MARCA
	COLD WATER / HOT WATER COIL	BATTERIES EAU FROIDE / EAU CHAude	KALTWASSER- / HEISSWASSER-SATZ	BATTERIE ACQUA FREDDA / ACQUA CALDA
20	2P/2R COIL	BATTERIE 2T/2R	KÜHLER 2T/2R	BATERIA 2T/2R
30	2P/3R COIL	BATTERIE 2T/3R	KÜHLER 2T/3R	BATERIA 2T/3R
21	4P/2R+1R COIL	BATTERIE 4T/2R+1R	KÜHLER 4T/2R+1R	BATERIA 4T/2R+1R
31	4P/3R+1R COIL	BATTERIE 4T/3R+1R	KÜHLER 4T/3R+1R	BATERIA 4T/3R+1R
2E	2P/2R COIL + ELECTRIC HEATER MODEL A10-A80-A90	2T/2R BATTERIE + CHAUFFAGE ELECTRIQUE TAILLE A10-A80-A90	2T/2R KÜHLER + ELEKTROHEIZUNGEN GRÖSSE A10-A80-A90	2T/2R BATTERIA + RISCALDAMENTO ELETTRICO MISURA. A10-A80-A90
3E	2P/3R COIL + ELECTRIC HEATER MODEL A10-A80-A90	2T/3R BATTERIE + CHAUFFAGE ELECTRIQUE TAILLE A10-A80-A90	2T/3R KÜHLER + ELEKTROHEIZUNGEN GRÖSSE A10-A80-A90	2T/3R BATTERIA + RISCALDAMENTO ELETTRICO MISURA. A10-A80-A90

REP.	GB	F	D	I	E
	ELECTRIC HEATING	CHAUFFAGE ELECTRIQUE	ELEKTROHEIZUNGEN	RISCALDAMENTO ELETTRICO	CALEFACCIÓN ELÉCTRICA
\$	WITHOUT HEATING	SANS CHAUFFAGE	OHNE HEIZUNG	SENZA RISCALDAMENTO	SIN CALEFACCIÓN
300W	BE1/BE2/BE3/BE4 : HEATING capacity in W (example in this case: 300w)	BE1/BE2/BE3/BE4 : puissance CANNE CHAUFFANTE en W (exemple dans ce cas 300w)	BE1/BE2/BE3/BE4 : Leistung HEIZROHR in W (z. B. in diesem Fall 300 W)	BE1/BE2/BE3/BE4 : potenza CANNA RISCALDANTE in W (esempio in questo caso 300w)	BE1/BE2/BE3/BE4 : potencia CALENADOR en W (ejemplo en este caso 300 W)
	WIRED SPEEDS	VITESSES CABLEES	DREHZAHLEN VERDRAHET	VELOCITÀ CABLADEAS	VELOCIDADES CABLEADAS
V1.V2.V3					
V1.V2.V4					
V1.V2.V5					
V1.V3.V4					
V1.V3.V5	SPEED CONFIGURATION	CONFIGURATION DES VITESSES	KONFIGURATION DER DREHZAHLEN	CONFIGURAZIONE DELLE VELOCITÀ	CONFIGURACIÓN DE VELOCIDADES
V1.V4.V5					
V2.V3.V4					
V2.V3.V5					
V2.V4.V5					
	SERVICE SIDE	FACE DE SERVICE	WARTUNGSSEITE	PANNELLO DI SERVIZIO	CARA DE SERVICIO
D	RIGHT	DROITE	RECHTS	DESTRA	DERECHA
G	LEFT	GAUCHE	LINKS	SINISTRA	IZQUIERDA
	AIR FILTERS	FILTRES A AIR	LUFFFILTER	FILTRI D'ARIA	FILTROS DE AIRE
\$	WITHOUT AIR FILTER	SANS FILTRE A AIR.	OHNE LUFTFILTER.	SENZA FILTRO D'ARIA.	SIN FILTRO DE AIRE
G1	STANDARD AIR FILTER	FILTRE A AIR STANDARD	STANDARD LUFTFILTER	FILTRO D'ARIA STANDARD	FILTRO DE AIRE ESTÁNDAR

REP	GB	F	D	E	REGULATIONS ELECTRONIQUE / ELECTROMECHANIQUE	ELEKTRONISCHE / EINSTELLUNGEN	REGOLAZIONE ELETTRONICA/ ELETROMECCANICA	REGULACIONES ELECTRÓNICA/ ELECTROMECÁNICA
B	ELECTROMECHANICAL REGULATION	REGULATIONS ELECTRONIQUE / ELECTROMECHANIQUE	ELEKTRONISCHE / EINSTELLUNGEN	REGULACIONES ELECTRÓNICA/ ELECTROMECÁNICA				
CMV	TERMINAL BLOCK	BORNIER	KLEMMENSTEIPEL	MORSETTIERA	COMMUTATORE MANUALE	TERMOSTATO + COMMUTATORE	TERMOSTATO + COMMUTATORE	CAJA DE BORNES
TBV	MANUAL SWITCH	COMMUTATEUR MANUEL	HANDSCHALTER	COMMUTATORE MANUALE	TERMOSTATO + COMMUTATORE	TERMOSTATO + COMMUTATORE	TERMOSTATO + COMMUTATORE	COMMUTADOR MANUAL
TBV1	THERMOSTAT + SWITCH (acts on valve and fan)	THERMOSTAT + COMMUTATEUR (action sur vanne et ventilation)	THERMOSTAT + SCHALTER (Wirkung auf Ventil und Lüftung)	(azione su valvola e ventilazione)	(azione su valvola e ventilazione)	(azione su valvola e ventilazione)	(azione su valvola e ventilazione)	(acción en válvula y ventilación)
TBMV	THERMOSTAT + SWITCH + CHANGE OVER (acts on valve and ventilation fan)	THERMOSTAT + COMMUT.+INV	THERMOSTAT + SCHALTER (Wirkung auf Ventil und Lüftung)	THERMOSTATO + COMMUTATORE (azione su valvola e ventilazione)	THERMOSTATO + COMMUTATORE	TERMOSTATO + COMMUTATO	TERMOSTATO + COMMUTATO	CONMUT. + INVERSOR (acción en válvula y ventilación)
TBMV1	THERMOSTAT + SWITCH + CHANGE OVER (acts on cooling valve and electric heat or cooling) (action sur vanne froide et/ou vanne chaude)	THERMOSTAT + INV + UMSCHALTER (Wirkung auf Kaltwasserventil und elektr. Heizelement oder Kaltwasserventil bzw. Warmwasserventil)	THERMOSTAT + INV (aktion sur vanne froide + UMSCHALTER (Wirkung auf Kaltwasserventil und elektr. Heizelement oder Kaltwasserventil bzw. Warmwasserventil))	ERSEUR (aktion sur vanne électrique ou vanne froide et/ou vanne chaude)	RE. + INVERTITORE (azione su valvola fredda e batteria elettrica fredda y batería eléctrica o válvula fría y/o válvula caliente)	TERMOSTATO + INVERTITORE (azione su valvola e ventilazione)	TERMOSTATO + INVERTITORE (acción en válvula y ventilación)	INVERSOR (acción en válvula y ventilación)
D	AQUANET Without valve – Cooling only (configuration A)	AQUANET Sans Vanne Froid Seul (configuration A)	AQUANET Ohne Ventil 'Nur Kühlung' (Konfiguration A)	AQUANET Senza Valvola Solo Freddo (configurazione A)	AQUANET Sin Válvula Solo Frío (configuración A)			
E	AQUANET With valve – Cooling only (configuration A)	AQUANET Avec Vanne Froid Seul (configuration A)	AQUANET Mit Ventil 'Nur Kühlung' (Konfiguration A)	AQUANET Con Valvola Solo Freddo (configuración A)	AQUANET Con Válvula Solo Frío (configuración A)			
F	AQUANET Without valve – Heating only (configuration A)	AQUANET Sans Vanne Chaud Seul (configuration A)	AQUANET Ohne Ventil Nur Heizung (Konfiguration A)	AQUANET Senza Valvola Solo Caldo (configurazione A)	AQUANET Sin Válvula Solo Calor (configuración A)			
G	AQUANET With valve – Heating only (configuration A)	AQUANET Avec Vanne Chaud Seul (configuration A)	AQUANET Mit Ventil Nur Heizung (Konfiguration A)	AQUANET Con Valvola Solo Caldo (configurazione A)	AQUANET Con Válvula Solo Calor (configuración A)			
H	AQUANET With valve – Heating only + IFC sensor (configuration A)	AQUANET Avec Vanne Chaud Seul + sonde IFC (configuration A)	AQUANET Mit Ventil Nur Heizung + Messfühler IFC (Konfiguration A)	AQUANET Con Valvola Solo Caldo + sonda IFC (configurazione A)	AQUANET Con Válvula Solo Calor + sonda IFC (configuración A)			
J	AQUANET Without valve – Heating only + IFC sensor (configuration A)	AQUANET Sans Vanne Chaud Seul + sonde IFC (configuration A)	AQUANET Ohne Ventil Nur Heizung + Messfühler IFC (Konfiguration A)	AQUANET Senza Valvola Solo Caldo + sonda IFC (configurazione A)	AQUANET Sin Válvula Solo Calor + sonda IFC (configuración A)			
L	AQUANET 4 Pipes with Valve (configuration E)	AQUANET 4 Tubes Avec Vanne (configuration E)	AQUANET 4 Leitungen mit Ventil (Konfiguration E)	AQUANET 4 Tubi Con Valvola (configurazione E)	AQUANET 4 Tubos Con Válvula (configuración E)			
M	AQUANET Cooling only Heating (configuration C)	AQUANET Froid Seul Chauffage (configuration C)	AQUANET Nur Kühlung Heizung (Konfiguration C)	AQUANET Solo Freddo (configurazione C)	AQUANET Solo Frío Calefacción (configuración C)	Riscaldamento (configurazione C)		
N	AQUANET Without Valve + Change Over (configuration B)	AQUANET REVerse Sans Vanne + Change Over (configuration B)	AQUANET Wärmepumpe ohne Ventil + Umschaltung (Konfiguration B)	AQUANET REVerse Senza Valvola + Change Over (configurazione B)	AQUANET REVerse Sin Válvula + Change Over (configuración B)			
P	AQUANET With Valve + Change Over (configuration B)	AQUANET REVerse Avec Vanne + Change Over (configuration B)	AQUANET Wärmepumpe mit Ventil + Umschaltung (Konfiguration B)	AQUANET REVerse Con Valvola + Change Over (configurazione B)	AQUANET REVerse Con Valvola + Change Over (configuración B)			
Q	AQUANET with Valve + Heating + Change Over (configuration D)	AQUANET REVerse Avec Vanne Chauffage + Change Over (configuration D)	AQUANET Wärmepumpe mit Ventil Heizung + Umschaltung (Konfiguration D)	AQUANET REVerse Con Valvola Riscaldamento + Change Over (configurazione D)	AQUANET REVerse Con Valvola Riscaldamiento + Change Over (configuración D)			

REP.	GB	F	VANNES	VENTILE	VALVOLE	E
\$	WITHOUT VALVE	SANS VANNE.	OHNE VENTIL.	SENZA VALVOLA.	SIN VÁLVULA	
2V/TOR/2T	2-WAY VALVE / OPEN-CLOSE / 2 PIPES	VANNE 2 VOIES / TOUT OU RIEN / 2 TUBES	2-WEGE-VENTIL / ALLES ODER NICHTS / 2 LEITUNGEN	VALVOLA 2 VIE / TUTTO O NULLA / 2 TUBI	VALVULA 2 VIAS/TODO O NADA/2 TUBOS	
2V/TOR/4T	2-WAY VALVE / OPEN-CLOSE / 4 PIPES	VANNE 2 VOIES / TOUT OU RIEN / 4 TUBES	2-WEGE-VENTIL / ALLES ODER NICHTS / 4 LEITUNGEN	VALVOLA 2 VIE / TUTTO O NULLA / 4 TUBI	VALVULA 2 VIAS/TODO O NADA/4 TUBOS	
4V/TOR/2T	4-WAY VALVE / OPEN-CLOSE / 2 PIPES	VANNE 4 VOIES / TOUT OU RIEN / 2 TUBES	4-WEGE-VENTIL / ALLES ODER NICHTS / 2 LEITUNGEN	VALVOLA 4 VIE / TUTTO O NULLA / 2 TUBI	VALVULA 4 VIAS/TODO O NADA/2 TUBOS	
4V/TOR/4T	4-WAY VALVE / OPEN-CLOSE / 4 PIPES	VANNE 4 VOIES / TOUT OU RIEN / 4 TUBES	4-WEGE-VENTIL / ALLES ODER NICHTS / 4 LEITUNGEN	VALVOLA 4 VIE / TUTTO O NULLA / 4 TUBI	VALVULA 4 VIAS/TODO O NADA/4 TUBOS	
2V/MOD/2T	2-WAY VALVE / MODULATING / 2 PIPES	VANNE 2 VOIES / MODULANTE 2 PIPES / 2 TUBES	REGULIEREND / 2 LEITUNGEN	VALVOLA 2 VIE / MODULANTE 2 TUBI	VALVULA 2 VIAS/ MODULANTE/2 TUBOS	
2V/MOD/4T	2-WAY VALVE / MODULATING / 4 PIPES	VANNE 2 VOIES / MODULANTE 4 PIPES / 4 TUBES	REGULIEREND / 4 LEITUNGEN	VALVOLA 2 VIE / MODULANTE 4 TUBI	VALVULA 2 VIAS/ MODULANTE/4 TUBOS	
4V/MOD/2T	4-WAY VALVE / MODULATING / 2 PIPES	VANNE 4 VOIES / MODULANTE 4 PIPES / 2 TUBES	REGULIEREND / 2 LEITUNGEN	VALVOLA 4 VIE / MODULANTE 2 TUBI	VALVULA 4 VIAS/ MODULANTE/2 TUBOS	
4V/MOD/4T	4-WAY VALVE / MODULATING / 4 PIPES	VANNE 4 VOIES / MODULANTE 4 PIPES / 4 TUBES	REGULIEREND / 4 LEITUNGEN	VALVOLA 4 VIE / MODULANTE 4 TUBI	VALVULA 4 VIAS/ MODULANTE/4 TUBOS	
AIR INTAKE		REPRISE D'AIR	LUFTEINNAHME	RIPRESA D'ARIA	RETIRO DE AIRE	
\$	WITHOUT AIR INTAKE OR UNIT WITHOUT CASING	SANS REPRISE OU APPAREIL NIU OHNE VERKLEIDUNG	OHNE ANSAUG ODER GERÄT OHNE VERKLEIDUNG	SENZA RIPRESA O APPARECCHIO NON RIVESTITO	SIN RETRNO O APARATO NO EQUIPADO	
MP	FEET	PIEDS	FÜSSE	PIEDINI	PATAS	
MPG	FEET + GRILLE	PIEDS + GRILLE	FUSSE + GITTER	PIEDINI + GRIGLIA	PIJILLAS + REJILLA	
RP	PARTIAL REAR AIR INTAKES	REPRISE PARTIELLE ARRIERE	TEILANSAAU HINTEN	RIPRESA PARZIALE POSTERIORE	RETORNO PARCIAL TRASERO	
RT	TOTAL REAR AIR INTAKE	REPRISE TOTALE ARRIERE	KOMPLETTER ANSAUG HINTEN	RIPRESA TOTALE POSTERIORE	RETORNO TOTAL TRASERO	
RC	UPFLOW AIR INTAKE	REPRISE EN CANIVEAU	ANSAUG IN KANAL	RIPRESA IN CONDOTTO	RETORNO EN CANALON	
RVCA-RT	REAR AIR INTAKE – AUTO FLAP	REPRISE ARRIERE VOLANT AUTO	ANSAUG HINTEN AUTOM SCHIEBER	RIPRESA POSTERIORE SPORTELLO AUTO	RETORNO TRASERO LAMA AUTO	
RVCA-RC	UPFLOW AIR INTAKE – AUTO FLAP	REPRISE CANIVEAU VOLANT AUTO	ANSAUG KANAL AUTOM SCHIEBER	RIPRESA CONDOTTO SPORTELLO AUTO	RETORNO DESAGUADERO LAMA AUTO	
RVCM-RT	REAR AIR INTAKE – MANUAL FLAP	REPRISE ARRIERE VOLANT MANUEL	ANSAUG HINTEN MANUELLER SCHIEBER	RIPRESA POSTERIORE SPORTELLO MANUALE	RETORNO TRASERO LAMA MANUAL	
RVCM-RV	UPFLOW AIR INTAKE – MANUAL FLAP	REPRISE CANIVEAU VOLANT MANUEL	ANSAUG KANAL MANUELLER SCHIEBER	RIPRESA CONDOTTO SPORTELLO MANUALE	RETORNO CANALON LAMA MANUAL	
THI	LOWER CASING PANEL	TOLE HABILLAGE INFÉRIURE	UNTERES VERKLEIDUNGSBLECH	LAMIERA RIVESTIMENTO INFERIOR	CHAPA REVESTIMIENTO INFERIOR	

REP	GB	F	D	E
	OPTIONS	OPTIONS	OPTIONEN	Opciones
RD	FRONT AIR INTAKE	REFRISSE EN FACADE	ANSAUG FRONTSEITIG	REFRISSE IN FAÇADE
RF	FRONT AIR INTAKE ASSY (CAR)	ENS/REPRISE FACADE (CAR)	SATZ/ANSAUG FRONTSEITIG (CAR)	INS/REPRISE FAÇCIATA (CAR)
RFAMOV	REMOVABLE FRONT AIR INTAKE ENS/REPRISE FACADE AMOVIBLE ASSY	CADRE REFOULEMENT AU SOUFFLAGE	SATZ/ANSAUG FRONTSEITIG ABNEHMBAR DRUCKSEITIGER RAHMEN AM AUSBLAS	INST/REPRISE FAÇCIATA AUTOMOBILE TELAIO MANDATA AL SOFFIAGGIO
CRG	AIR OUTLET AIR FRAME			FRONTAL EXTRAIBLE MARCO DESCARGA EN LA IMPULSIÓN
PF				
PF1	FUSE HOLDER	PORTE FUSIBLE	SICHERUNGSSHALTER	PORTAFUSIBLES
PF2				
C/O	MECHANICAL CHANGE OVER (cycle inversion)	SONDE MECANIQUE CHANGE OVER (inversion cycle)	MECHANISCHER CHANGE OVER (zyklusumkehr)	SONDA MECÁNICA,CHANGE OVER (inversión ciclo)
BAC	AUXILIARY TRAY	BAC AUXILLAIRE	HILFSWANNE	VASCA AUXILIARE
ALV	REAR CASING PANEL	PANNEAU HABILLAGE ARRIERE	HINTERE GEHAUSEPLATTE	PANNELLO RIVESTIMENTO POSTERIORE
PRC	CONDENSATE LIFT PUMP	POMPE RELEVAJE CONDENSATS	KONDENSWASSERHEBEPUMPE	POMPA SOLLEVAMENTO CONDENSATI
RCL	REMOTE CONTROL	TELECOMMANDE	FERNBEDIENUNG	TELECOMANDO
NIU	µBMS/RCW2 REMOTE CONTROL INTERFACE (AIRCONET/MODBUS)	INTERFACE TELECOMMANDE µBMS/RCW2	SCHNITTSTELLE FERNBEDIENUNG µBMS/RCW2	INTERFAZ TELECOMANDO DISTANCIA µBMS/RCW2
eNIU	INTERFACE (AIRCONET/MODBUS)	(AIRCONET/ MODBUS)	SCHNITTSTELLE (AIRCONET/ MODBUS)	INTERFAZ (AIRCONET/ MODBUS)
SEH	CHANGE OVER SENSOR	SONDE CHANGE OVER	MESSFEUHLER UMSCHALTER	SONDA CHANGE OVER
REL/CH	HEATING RELAY	RELAIS CHAUFFAGE	RELAIS HEIZUNG	RELE RISCALDAMENTO

APPENDIX / ANEXE / ANLAGE / ALLEGATO / ANEXO

EXAMPLE

EXEMPLE

BEISPIEL

ESEMPIO

EJEMPLO

A40.W.C.\$.30.1000W.V1.V2.V4.G.G1.B.4V/TOR/2T.MPG.+ALV

A40:	MODEL 40
W:	CONSOLE MOUNTING
C:	MODEL WITH CASING
\$:	NO BRAND
30:	2P/3R COIL
1000W:	HEATING CAPACITY IN W
V1.V2.V4:	SPEED CONFIGURATION
G:	SERVICE SIDE (LEFT)
G1:	STANDARD AIR FILTER
B:	TERMINAL BLOCK
4V/TOR/2T:	4-WAY VALVE / OPEN-CLOSE / 2 PIPES
MPG:	FEET+GRILLE
ALV:	REAR CASING PANEL

A40:	MODELE 40
W:	MONTAGE ALLEGÉ MURAL
C:	MODELE CARROSSE
\$:	SANS MARQUE
30:	BATTERIE 2T/3R
1000W:	PUISANCE CANNE CHAUFFANTE EN W
V1.V2.V4:	VITESSES CABLEES
G:	FACE DE SERVICE GAUCHE
G1:	FILTRE A AIR STANDARD
B:	BORNIER
4V/TOR/2T:	VANNE 4 VOIES / TOUT OU RIEN / 2 TUBES
MPG:	PIEDS+GRILLE
ALV:	PANNEAU HABILLAGE ARRIERE

A40:	MODELL 40
W:	WANDMONTAGE MIT STÜTZMAUER
C:	MODELL MIT VERKLEIDUNG
\$:	OHNE MARKE
30:	KÜHLER 2T/3R
1000W:	LEISTUNG HEIZROHR IN W
V1.V2.V4:	KONFIGURATION DER DREHZAHLEN
G:	WARTUNGSSEITE LINKS
G1:	STANDARD LUFTFILTER
B:	KLEMMENLEISTE
4V/TOR/2T:	4-WEGE-VENTIL / ALLES ODER NICHTS / 2 LEITUNGEN
MPG:	FÜSSE+GITTER
ALV:	HINTERE GEHÄUSEPLATTE

A40:	MODELLO 40
W:	MONTAGGIO DAVANZALE MURALE
C:	MODELLO CAROZZATO
\$:	SENZA MARCA
30:	BATTERIA 2T/3R
1000W:	POTENZA CANNA RISCALDANTE IN W
V1.V2.V4:	CONFIGURAZIONE DELLE VELOCITÀ
G:	PANNELLO DI SERVIZIO SINISTRA
G1:	FILTRO D'ARIA STANDARD
B:	MORSETTIERA
4V/TOR/2T:	VALVOLA 4 VIE / TUTTO O NULLA / 2 TUBI
MPG:	PIEDINI+GRIGLIA
ALV:	PANNELLO RIVESTIMENTO POSTERIORE

A40:	MODELO 40
W:	MONTAJE ALFEIZAR MURAL
C:	MODELO CON ENVOLVENTE
\$:	SIN MARCA
30:	BATERÍA 2T/3R
1000W:	POTENCIA CALENTADOR EN W
V1.V2.V4:	CONFIGURACIÓN DE VELOCIDADES
G:	CARA DE SERVICIO IZQUIERDA
G1:	FILTRO DE AIRE ESTÁNDAR
B:	CAJA DE BORNES
4V/TOR/2T:	VÁLVULA 4 VÍAS/TODO O NADA/2 TUBOS
MPG:	PATAS + REJILLA
ALV:	PANEL REVESTIMIENTO TRASERO

EC Compliance declaration

Under our own responsibility, we declare that the product designated in this manual comply with the provisions of the EEC directives listed hereafter and with the national legislation into which these directives have been transposed.

Déclaration CE de conformité

Nous déclarons sous notre responsabilité que les produits désignés dans la présente notice sont conformes aux dispositions des directives CEE énoncées ci-après et aux législations nationales les transposant.

EG-Konformitätserklärung

Wir erklären in eigener Verantwortung, dass die in der vorliegenden Beschreibung angegebenen Produkte den Bestimmungen der nachstehend erwähnten EG-Richtlinien und den nationalen Gesetzesvorschriften entsprechen, in denen diese Richtlinien umgesetzt sind.

Dichiarazione CE di conformità

Dichiariamo, assumendone la responsabilità, che i prodotti descritti nel presente manuale sono conformi alle disposizioni delle direttive CEE di cui sott e alle legislazioni nazionali che li recepiscono

Declaración CE de conformidad

Declaramos, bajo nuestra responsabilidad, que los productos designados en este manual son conformes a las disposiciones de las directivas CEE enumeradas a continuación, así como a las legislaciones nacionales que las contemplan.

AQU@FAN II - Type AWC / AHC / AWN / AHN
Mod: 10-20-30-40-50-60-70-80-90

LOW VOLTAGE DIRECTIVE 2006 / 95 / EC
ELECTROMAGNETIC COMPATIBILITY DIRECTIVE 89 / 336 / EC AMENDED BY 92 / 31 / EC AND 93 / 68 / EC
PRESSURISE EQUIPMENT DIRECTIVE 97 / 23 / EC
SUB-MODULE A CATEGORY I

DIRECTIVE BASSE TENSION 2006 / 95 / C.E.E.
DIRECTIVE COMPATIBILITE ELECTROMAGNETIQUE 89 / 336 / C.E.E. AMENDEE PAR DIRECTIVE 92 / 31 / C.E.E ET 93 / 68 / C.E.E
DIRECTIVE DES EQUIPEMENTS SOUS PRESSION 97 / 23 / C.E.E.
SOUS-MODULE A CATEGORIE I

RICHTLINIE NIEDERSPANNUNG 2006 / 95 / EG
RICHTLINIE ELEKTROMAGNETISCHE VERTRÄGLICHKEIT 89 / 336 / EG ABGEÄNDERT DURCH DIE RICHTLINIE 92 / 31 / EG UND 93 / 68 / EG
RICHTLINIE FÜR AUSRÜSTUNGEN UNTER DRUCK 97 / 23 / EG
UNTER MODUL A, KATEGORIE I

DIRETTIVA BASSA TENSIONE 2006 / 95 / CEE
DIRETTIVA COMPATIBILITA ELETTROMAGNETICA 89 / 336 / CEE EMENDATA DALLA DIRETTIVA 92 / 31 / CEE E 93 / 68 / CEE
DIRETTIVA DEGLI IMPIANTI SOTTO PRESSIONE 97 / 23 / CEE
SOTTOMODULO A, CATEGORIA I

DIRECTIVA BAJA TENSION 2006 / 95 / CEE
DIRECTIVA COMPATIBILIDAD ELECTROMAGNETICA 89 / 336 / CEE ENMENDADA POR LA DIRECTIVA 92 / 31 / CEE Y 93 / 68 / CEE
DIRECTIVA DE LOS EQUIPOS A PRESION 97 / 23 / CEE
BAJA MODULO A, CATEGORIA I

And that the following paragraphs of the harmonised standards have been applied.

Et que les paragraphes suivants les normes harmonisées ont été appliqués.

Und dass die folgenden Paragraphen der vereinheitlichten Normen Angewandt wurden.

E che sono stati applicati i seguenti paragrafi delle norme armonizzate.

Y que se han aplicado los siguientes apartados de las normas armonizadas.

EN 60 335-1
EN 55 014-1

EN 60 335-2-40
EN55 014-2


A Tillieres Sur Avre
27570 - FRANCE
Le: 27/04/2007
Franck Baily
Quality Manager
ACE Industrie



ACE
Industrie

As part of our ongoing product improvement programme, our products are subject to change without prior notice. Non contractual photos.

Dans un souci d'amélioration constante, nos produits peuvent être modifiés sans préavis. Photos non contractuelles.



ACE Industrie
Route de Verneuil
27570 Tillières-sur-Avre
France

(€) : +33 (0)2 32 60 61 00

fax : +33 (0)2 32 32 55 13